



E.L. Haynes PCS (Kansas Ave) - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
E.L. Haynes PCS [Kansas Ave]	WS-025-001	Cooler	1	In hallway adjacent to room 106			WF-072019-025001-02	11/9/2019	FT-FY20-072019-025001-A	<1	FT-FY20-072019-025001-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-002	Cooler	1	In hallway adjacent to room 121			WF-072019-025002-03	11/9/2019	FT-FY20-072019-025002-A	<1	FT-FY20-072019-025002-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-003	Cooler	2	In hallway adjacent to room 223			WF-072019-025003-03	11/9/2019	FT-FY20-072019-025003-A	<1	FT-FY20-072019-025003-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-004	Cooler	2	In hallway across from room 211			WF-072019-025004-03	11/9/2019	FT-FY20-072019-025004-A	<1	FT-FY20-072019-025004-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-005	Cooler	3	In hallway across from room 310			WF-072019-025005-03	11/9/2019	FT-FY20-072019-025005-A	<1	FT-FY20-072019-025005-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-006	Cooler	3	In hallway adjacent to room 315A			WF-072019-025006-03	11/9/2019	FT-FY20-072019-025006-A	<1	FT-FY20-072019-025006-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-007	Food Prep Sink	1	In kitchen room 137 in auditorium			WF-072019-025007-03	11/9/2019	FT-FY20-072019-025007-A	<1	FT-FY20-072019-025007-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-008	Food Prep Sink	1	In cafeteria			WF-072019-025008-03	11/9/2019	FT-FY20-072019-025008-A	<1	FT-FY20-072019-025008-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-009	Cooler	2	In hallway adjacent to room 213	Low	Right	WF-072019-025009-03	11/9/2019	FT-FY20-072019-025009-A	<1	FT-FY20-072019-025009-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-010	Cooler	2	In hallway adjacent to room 213	High	Left	WF-072019-025010-03	11/9/2019	FT-FY20-072019-025010-A	<1	FT-FY20-072019-025010-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-011	Cooler	1	In hallway adjacent to room 112	Low	Right	WF-072019-025011-03	11/9/2019	FT-FY20-072019-025011-A	<1	FT-FY20-072019-025011-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-012	Cooler	1	In hallway adjacent to room 112	High	Left	WF-072019-025012-03	11/9/2019	FT-FY20-072019-025012-A	<1	FT-FY20-072019-025012-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-013	Cooler	Basement	In hallway adjacent to gym	Low	Right	WF-072019-025013-03	11/9/2019	FT-FY20-072019-025013-A	<1	FT-FY20-072019-025013-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-014	Cooler	Basement	In hallway adjacent to gym	High	Left	WF-072019-025014-03	11/9/2019	FT-FY20-072019-025014-A	<1	FT-FY20-072019-025014-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-015	Health Suite	2	In health suite room 207			WF-072019-025015-03	11/9/2019	FT-FY20-072019-025015-A	<1	FT-FY20-072019-025015-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-016	Cooler	2	In hallway adjacent to room 203			WF-072019-025016-03	11/9/2019	FT-FY20-072019-025016-A	<1	FT-FY20-072019-025016-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-017	Cooler	3	In hallway across from LEA office room 323			WF-072019-025017-03	11/9/2019	FT-FY20-072019-025017-A	<1	FT-FY20-072019-025017-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-018	Classroom Faucet	1	In classroom 102			WF-072019-025018-03	11/9/2019	FT-FY20-072019-025018-A	<1	FT-FY20-072019-025018-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-019	Classroom Faucet	1	In classroom 103			WF-072019-025019-03	11/9/2019	FT-FY20-072019-025019-A	<1	FT-FY20-072019-025019-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-020	Classroom Faucet	1	In classroom 106			WF-072019-025020-03	11/9/2019	FT-FY20-072019-025020-A	<1	FT-FY20-072019-025020-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-021	Classroom Faucet	1	In classroom 116			WF-072019-025021-03	11/9/2019	FT-FY20-072019-025021-A	<1	FT-FY20-072019-025021-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-022	Classroom Faucet	1	In classroom 117			WF-072019-025022-03	11/9/2019	FT-FY20-072019-025022-A	<1	FT-FY20-072019-025022-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-023	Classroom Faucet	1	In classroom 121			WF-072019-025023-03	11/9/2019	FT-FY20-072019-025023-A	<1	FT-FY20-072019-025023-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-031	Break Room	1	In PD room 112 in kitchenette			WF-072019-025031-02	11/9/2019	FT-FY20-072019-025031-A	<1	FT-FY20-072019-025031-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-032	Classroom Faucet	1	In classroom 102		Right	WF-072019-025032-02	11/9/2019	FT-FY20-072019-025032-A	3.8	FT-FY20-072019-025032-B	<1
E.L. Haynes PCS [Kansas Ave]	WS-025-033	Classroom Faucet	1	In classroom 106		Left	WF-072019-025033-03	11/9/2019	FT-FY20-072019-025033-A	<1	FT-FY20-072019-025033-B	<1